

## Tabela regulacyjna wody sieciowej 135/70°C

L.p.	Temperatura zewnętrzna	Temperatury zasilania.	Temperatury powrotu
1	2	3	4
1	-20	<b>135</b>	<b>70</b>
2	-19	133	69
3	-18	130	68
4	-17	128	67
5	-16	125	66
6	-15	123	65
7	-14	121	64
8	-13	118	63
9	-12	115	62
10	-11	113	61
11	-10	111	60
12	-9	108	59
13	-8	105	58
14	-7	102	57
15	-6	99	56
16	-5	97	55
17	-4	95	54
18	-3	93	53
19	-2	91	52
20	-1	88	51
21	0	86	50
22	1	84	49
23	2	81	48
24	3	79	47
25	4	76	46
26	5	72	45
27	6	69	44
28	7	66	43
29	8	63	42
30	9	59	41
31	10	56	40
32	11	53	39
33	12	50	38