

Tabela regulacyjna wody sieciowej 80/60°C

L.P.	Temperatura zewnętrzna	Temperatura zasilania	Temperatura powrotu
1	2	3	4
1	-20	<b>80</b>	<b>60</b>
2	-19	79	59
3	-18	77	58
4	-17	76	58
5	-16	75	57
6	-15	74	56
7	-14	72	55
8	-13	71	55
9	-12	70	54
10	-11	69	53
11	-10	67	52
12	-9	66	51
13	-8	65	51
14	-7	63	50
15	-6	62	49
16	-5	61	48
17	-4	59	47
18	-3	58	46
19	-2	56	45
20	-1	55	45
21	0	54	44
22	1	52	43
23	2	51	42
24	3	49	41
25	4	48	40
26	5	47	39
27	6	45	38
28	7	44	37
29	8	42	36
30	9	41	35
31	10	39	34
32	11	37	33
33	12	36	32